DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Farms V _____ APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: 5/9/06
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 563 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRIC CLASS	.1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1	pit #10 L	0-22	Mo SBK C	FR SS/SP	Red		Fsap		0.3
		22-32	Mo SBK C	FR SS/SP	Red		csap		
		32-48	WK SBK CL	FR SS/SP	Lt Red Br				
2	L 1%	0-6	WK sbk scl	fr ss/sp	Red Br				0.3
		6-52	mo sbk C	fr ss/sp	Red				
3	L	0-22	WK sbk C	fr ss/sp	Red		F/C sap		0.3
		22-52	mo sbk cl	fr ss/sp	Red				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____

795
800
805
810
800
805
110.29'
WELL #24
100'
L=176.42'
127.77'
157.36'
8.5
563A
#2
#3
616
0.94 acres
260.00'
562A
IDREE
OHU
OHU
OHU
12W
12W
12W
12W
12W
12W
60'