IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 139343 PIN# ~~4626-58-1913.585~~ 4626583101 DATE March 5, 2007

OWNER OR APPLICANT The FARMS LLC / HELMS BUILDERS PHONE: Business _____ Home _____

ADDRESS 2214 Brawley Sch Rd, Mooresville, N.C. 28117

LOCATION Brawley Sch Rd. - TR McKendree - TR Grasshopper TR Cherry Tree corner of Cherry Tree and Bells Run Ct.

SUBDIVISION The FARMS BLOCK / SECTION 5 LOT 585 LOT AREA .83AC SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank: * 1500 Gallons: STB 390 Date 3/1/07

Pump Tank: * 1500 Gallons: PT 353 Date 5/1/07

Pump Make: MYERS Model ME-50-21 Serial No. 2796A004

Nitrification Field: No Fields ___ Square Feet 540 Linear Feet 270

No Lines 3 Trench Width 24" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP PUBS

Repair System Description: LP PUBS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons ___

☐ Business No. Employees ___

☐ Other

Water Supply: ☐ Individual ☒ Public ☒ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: * Per plan specs
Properly fill gullied areas. Slight shaping may be required in

Comments/Conditions: *Reviewed Plans, essentially same as IP 12/19/07 A.C.
62 Panels -

INITIAL SITE SKETCH

SEE Plan from SAME

AS BUILT SKETCH

The proposed / existing DECK ADDITION addition does not appear to impact the existing septic system.

**NOTE: _____ REHS

Date: 8-18-08

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 4-3-07 Installed by: Stanley Septic Service

Improvement Permit by: _____ date 3-5-07 Operation Permit by: Wesley Sparks R.S. date 9/11/08

Authorization to Construct by: Anthony Cohen date 12/17/07 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK