DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Farms V _____ APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: _____
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 591 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	L	0-18	Mo SBK C	FR SS/SP	Red				0.25-
		18-30	Mo SBK C	FR SS/SP	Red; F Yel Br				0.275
		30-46	Mo SBK C/L	FR SS/SP	Red		F Sap		
2		0-6	WkSBK sandy L	Friable SS/SP					.3
		6-35	SBK sdc	Friable SS/SP					
		35-48	WkSBK sdc	Friable SS/SP common Sap					
3	5%	0-15	WkSBK sdc	Friable SS/SP					.3
		15-30	WkSBK sdc	Friable SS/SP Laminations in upper					
		30-52	WkSBK sdc	Friable SS/SP common Sap Manganese					
4		0-6	M Sand SL	Friable SS/SP					.3
		6-22	WkSBK sdc	Friable SS/SP					
		22-46	WkSBK sdc	Friable SS/SP common inclusions					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____