IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☑ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 139335/17212B PIN # 4626-58-8068 DATE 4-10-12

OWNER M1 HOMES APPLICANT: SAME PHONE: Home/Cell # 704-402-7882 Business #

SITE ADDRESS STAMFORD CT OWNER / APPLICANT ADDRESS 9335 HARRIS CORNERS PARKWAY

SITE DIRECTIONS RSR, MCKENDREE, GRASSHOPPER, CHERRY TREE, STAMFORD

SUBDIVISION THE FARMS BLOCK / SECTION 5 LOT # 578 LOT AREA .719 AC DESIGN FLOW 600GPD L.T.A.R. .25

Septic Tank 1500 Gallons: STB 444 Date 7-15-12
Pump Tank 1500 Gallons: PT 477 Date 7-22-12
Pump Make ____ Model ____ Serial # ____
No. Nitrification Fields: 1 No. Lines 4 Linear Feet 400'
Trench Width 24"-36" Max. Trench Bottom Depth *33" Gravel Depth —

☑ New System ☐ Repair ☐ Expansion System Type I II III (IV) V VI
System Description: LP-PANEL BLOCK
Repair System Description: SAME
Maintenance Agreement Required ☒ YES ☐ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 5
☐ Business No. Persons ____
☐ Other No. Employees ____
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply
☐ Private
☐ Public
☒ Community

Comments / Conditions * PER PLAN SPECS *

INITIAL SITE SKETCH

SEE ATTACHED PLAN
BY
MICHAEL ATHANAS & ASSOC.
APPROVED BY
ICHD

AS BUILT SKETCH

INSTALLED AS DRAWN
CHECKED LINES & TANKS 8-31-12
SET PH 2'

SEE ATTACHED REVISION FOR POOL
RA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☒ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ~~site plan valid 60 mo.~~ ☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Ken King Date 4-13-12 Installed by: ABERNATHY

IMPROVEMENT PERMIT by: R.A. REHS Date 4-10-12 OPERATION PERMIT by: R.A. REHS Date 10-10-12

AUTHORIZATION TO CONSTRUCT by: R.A. REHS Date 4-10-12 Existing System Inspected by: REHS Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy -- Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant