DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: MI Homes APPLICATION DATE: 9-1-12
ADDRESS: DATE EVALUATED:8-15-12
PROPOSED FACILITY: 5 BR. PROPOSED DESIGN FLOW (.1949): 600GPD PROPERTY SIZE: .71
LOCATION OF SITE: Stamford Court, Lot 578 PROPERTY RECORDED:
WATER SUPPLY: *Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: * Auger Boring Pit ☐ Cut TYPE OF WASTEWATER: * Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
P 1	LS 3-5%	0-8	Br. SCL WSBK	FR SS/SP SEXP	Few Sap Incl.	48'			PS .3+
		8-24	R Clay SBK	FI-FR SS/SP SEXP					
		24-48	R CL WSBK	FR SS/SP SEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: MA & ASSOC.
OTHER(S) PRESENT:

COMMENTS: