DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Crescent Resources Inc APPLICANT: Tony Jacobs
ADDRESS: 400 S. Tryon St APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: 4BR PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: ____
LOCATION OF SITE: Harbor Lot #2 PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☑ Other community
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3%	0-24	C SBK	FI S,P					PS .3
		24-48	CL W-MSBK	FI SS,SP					
2	3%	0-20	CL W-MSBK	FI SS,SP					PS .3
		20-48	CL W MSBK	FRI SS,SP					
3	3%	0-6	SCL FR-WSBK	FRI SS,SP					PS .3
		6-24	C MSBK	FI S,P					
		24-48	CL M-WSBK	FRI SS,SP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200	810
System Type(s)	Gravity Chambers	Gravity Pump
Site LTAR	.3	.3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Brady Freeman
OTHER(S) PRESENT: Paul Pennington