IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

DATE 7-21-06

PERMIT# 112519 PIN# 4626637315.227 PHONE: Business 704-795-1733 Home 980-722-8454 (cell)

OWNER OR APPLICANT Lifestyle Custom Homes

ADDRESS 5706 Burck Dr Concord 28027

LOCATION Brawley School Rd TR Southfork TL Freshwater on right (Easement: Brawley SR TR gravel rd past Morrows chapel on left)

SUBDIVISION The Farms BLOCK / SECTION 2 LOT 227/227A LOT AREA .89 Ac SITE CLASS. PS DESIGN FLOW 600 gpd L.T.A.R. .3 gpd/ft²

Septic Tank: 1500 Gallons; STB 338 Date 12-8-06

Pump Tank: 1500 Gallons; PT 477 Date 11-27-06

Pump Make: Goulds Model VE1512HC Serial No.

Nitrification Field: No Fields 1 Square Feet 2000 Linear Feet 335

No Lines 3 Trench Width 24" min 36" max. Max Trench Bottom Depth 36"

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

Gravel Depth NA ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home No. Bedrooms 5

☐ Mobile Home No. Persons 10

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☐ Public ☒ Community

Comments:/Conditions: 77 panels

Comments:/Conditions: Checked tanks & Supply line 2/22/07 2/27/07 Re-evaluate Drainfield okay to add 40 @ 25-25% Reduction Test alarm 2/28/07 Checked Pressure, Lines, Test alarm

INITIAL SITE SKETCH

1" = 100'

KMP 2/27/07

PT

Supply Pipe

1" = 50'

227A

210'

30' 1/2'

Repair

House

Freshwater

Driveway

CVB

Repair

20' Gravel Road

Morrows Chapel

Brawley School Rd

AS BUILT SKETCH

See attached "As Built"

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

☐ Permit with plat valid without expiration ☒ Improvement Permit with site plan valid for sixty months

Signed: Billy Lo date 7-24-06 Installed by: Hallman Construction date

Improvement Permit by: Judy Melville date 7-21-06 Operation Permit by: date

Authorization to Construct by: Judy Melville date 7-21-06 Existing System Inspection by:

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

~20' to edge of Road