IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jane Cook DATE 6-2-78 PERMIT NO. 106

PHONE: Business _____ Home _____

LOCATION 160 R on 1178 L on 1234 at end on Right S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 485 SECTION OR BLOCK NO. 8

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6'+
			Rock or other impervious formations	None

Lot Area 3/4 acre



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Danny Tucker

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 6-2-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold