4626687190

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR S.L. Taylor Jr. DATE 8-21-25 PERMIT NO. 195

PHONE: Business 233-0541 Home 233-0541


LOCATION 1100 TO on 1334 next to last lot on right S. R. No. 1334

SUBDIVISION NAME Lake Norman LOT NO. 49 SECTION OR BLOCK NO. 2

House ( ) Mobile Home ( ) Business ( ) Other Double Wide mobile home

No. Bedrooms 3 No. Bathrooms 2

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No ( ) | Character & Porosity of Soil | Clay loam |
| Auto. Dishwasher | Yes ( ) | No ( ) | Percolation Rate | 2 in 20 min |
| Auto. Wash. Machine | Yes ( ) | No ( ) | Topography | Level |
| Site Suitable | Yes ( ) | No ( ) | Depth to Water Table | 10' |
| Lot Area 3 Acres | | | Rock or other impervious formations | none |



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public ( )

Installed by Clint Kelly (Carolina Co)

IMPROVEMENTS PERMIT BY [illegible]

COMMENTS: [illegible]

CERTIFICATE OF COMPLETION BY [illegible] DATE [illegible]

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

4626687190

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR S. L. Jordan DATE 5-21-05 PERMIT NO. 194

PHONE: Business 872-4811 Home 320-4701

LOCATION 1100 TR 60 on 1st left past 4 lane

2nd on right S. R. No. 1229

SUBDIVISION NAME Lowe's Narrows LOT NO. 491 SECTION OR BLOCK NO. 5

House ( ) Mobile Home ( ) Business ( ) Other Double wide mobile Home

No. Bedrooms 3 No. Bathrooms 2

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes | ( ) | No | (X) |
| Auto. Dishwasher | Yes | (X) | No | ( ) |
| Auto. Wash. Machine | Yes | (X) | No | ( ) |
| Site Suitable | Yes | (X) | No | ( ) |

Lot Area 2 acre


Character & Porosity of Soil Clay Loam (moderate)

Percolation Rate Not Done

Topography Slope 2% Slope to line

Depth to Water Table 10' to Zero Level

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 225 Linear Ft. 250

Depth of Stone in Lines 24"

Water Supply: Individual ( )

Public ( )

Installed by _____

Ditch 7½' wide 84' long

IMPROVEMENTS PERMIT BY L. A. Morgan

COMMENTS: Morgan

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold