IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 218385

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4026-70-6170

APPLICANT: JEFF FINK APPLICANT ADDRESS: PO Box 3515 Mooresville, NC 28117

SITE ADDRESS: 134 Well Fleet Ln - Mooresville PHONE: 704-651-5420 ALT. PHONE:

SITE DIRECTIONS: BSR, TR Marston's Mill, TR White House, TR Tuckernuck, TR Well Fleet, C END

SUBDIVISION: The Point on Norman SECTION: 4 LOT # 394 LOT AREA: 1.7 AC DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank 1000 (gal) STB 338 Date 4-5-05
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 5@80' Linear Ft: 400
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II ☒ III IV V VI
System Description: EZ Flow
Repair System Description: DRIP
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☐ Residence No. Bedrooms 4
☐ Business No. Persons
☒ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions:

RELOCATING REPAIR TO ACCOMODATE A POOL

INITIAL SITE SKETCH

See Plan From Michael Athanas & Associates

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 5/25/16 Installed by:

IMPROVEMENT PERMIT by: APPROVED Date: MAY 16 2016 OPERATION PERMIT by: APPROVED Date: MAY 16 2016

AUTHORIZATION TO CONSTRUCT by: APPROVED Date: MAY 16 2016 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK


plat book _____, page _____, that the ratio of precision is 1:10,000; that this map was prepared in accordance with the General Statutes of North Carolina Chapter 89C.

my hand and seal on the 28TH, day of JULY, A.D. 2016

NORTH CAROLINA PROFESSIONAL SEAL L-3599 LAND SURVEYOR WILLIAM M. ALLEN

WILLIAM M. ALLEN PLS

APPROVED MAY 16 2016



BAY HARBOUR ROAD
60' PUBLIC R/W

LOT 382
COMMON OPEN SPACE

THE POINT ON NORMAN
HOLE #4

LOT 395
BEALER HOMES
DB. 1563, PG. 248

LOT 394
1.70 AC.

LOT 393
MARSHALL CROOM
DB. 1535, PG 2216

PB. 35 PG. 137

CONCRETE MONUMENT

#4 REBAR

EIP

R/W

60.00'

30' SETBACK

20' SETBACK

110' SETBACK

CONCRETE DRIVE & WALK

Addition / Repair

Repair

Area

Pool

Pool Deck

Stone Patio

Brick

2-Story Stucco & Stone Roof Comp.

Iron Fence

Brick

Brick

Brick

Brick

Brick

CURVE	RADIUS	LENGTH	CHORD	BEARING
C1	660.92'	259.96'	258.29'	S 73°25'11" E
C2	660.92'	123.20'	123.02'	N 89°58'13" E
C3	50.00'	32.01'	31.47'	N 24°21'06" W

LINE	DIRECTION	DISTANCE
L1	S 05°21'59" E	39.25'
L2	S 79°05'42" W	87.50'
L3	S 56°05'35" W	62.38'
L4	S 36°41'01" W	39.18'

N 61°47'49" E 240.13'

N 86°22'11" W 287.04'

S 74°44'18" W BASE BEARING 200.71'

N 37°49'11" E 111.39'

132.6'

99.7'

153.0'

49.0'

44.6'

LEGEND

P.P. = POWER POLE

DUKE POWER TRANS.

E.I.P. = EXISTING IRON FOUND

I.P.S. = #4 REBAR SET

R/W = RIGHT-OF-WAY

W = WELL

BTL = BUILD TO LINE

LP = LIGHT POLE

PDE = PUBLIC DRAINAGE EASEMENT

0' 30' 60' 100'

SCALE IN FEET

NOTES

1) THIS PROPERTY MAY BE SUBJECT TO ANY EASEMENTS AND/OR RIGHTS OF WAY OF RECORD.

PHYSICAL SURVEY