DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____ OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RSMB Enterprises OWNER:__ AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE: 3/14/95 DATE EVALUATED: 3/16/95
PROPOSED FACILITY: 3 BR 2 Bath House
PROPERTY SIZE: 127 x 251
LOCATION OF SITE: 1100 L Leon McIntree, Rt on Carrie, at Corner
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other_____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	F 10/270	0-2	Organic/Clay		—	—	—	—	≈0.3
		2-42	1:1 Cly ABC		Non	None	PS		
2	N 10-17	0-8	Organic Sandy		Non	Non	PS	—	≈0.3
		8-48	1:1 Cly ABC						
3									
4									
5									

AVAILABLE SPACE (.1945): Ps SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: ≈0.3
EVALUATED BY: ICS OTHER(S) PRESENT: Mike Martin
COMMENTS: Conv. on Natural Ridge 3 or 4 lines. PP BDS Repair Gravity