SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

..ER: Lee Foster APPLICANT: Same
DRESS: APPLICATION DATE: DATE EVALUATED: 10/25/00
)POSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
CATION OF SITE: Lot 8 BB Green ph 2 PROPERTY RECORDED:
TER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
ALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
PE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-10	bscl vfr	FAL sssp					PS .25
	10-56	RBL sbk	FI sp	Common Sat	of Manganese			
	0-24	RC sbk	FI sp					PS .3
	24-58	RCL wsbk	FRI ssp	Few SAP				
	0-12	RC sbk	FI sp					PS .35
	12-44	RCL wsbk	FRI ssp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ilable Space (.1945)		
em Type(s)		
LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: CBF
OTHER(S) PRESENT: