4626781439

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Grant Lee DATE 5-9-86 PERMIT NO. 268

PHONE: Business _____ Home _____

LOCATION 1100 before Trading Post TR on Beech Tree Road at 90° curve on Rt S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 495 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other adding 2 bedrooms & 3baths

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area _____

Character & Porosity of Soil clayed
Percolation Rate .4 gal/ft²/day
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System Road

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual (✓)
Public ( )

TJ panel 2 rows 75'
10' panels 24" ditch - 1's and under panel
Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

The location of the proposed Deck Extension addition does not appear to impact the existing septic system.
**NOTE: _____
Mary Melville REHS
Date: 12-7-10
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY Charles K. Bennett DATE 5-9-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT 1130

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Grant Lee DATE 4-17-86 PERMIT NO. 176

PHONE: Business _____ Home _____

LOCATION 1100 before Trading Post TR on Beech Tree Road at 90° Curve on Rt.

SUBDIVISION NAME Lake Norman LOT NO. 495 SECTION OR BLOCK NO. 8 S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other Adding 2 bedrooms 3 baths


No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____

Character & Porosity of Soil Clayey
Percolation Rate 4
Topography 2 to 20
Depth to Water Table 10'+
Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual (✓) T & J Panel System
Public ( )
2-75' rows @ 16" Panels
24" ditch 1' Sand under Panels
Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: x Larry Beam
Contractor

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold