IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Crowe DATE 8-27-74 PERMIT NO. 231

PHONE: Business _____ Home 596-1906

LOCATION 1100 TR on 1234 1½ mi TR on dirt Rd at end on right S. R. No. 1234


SUBDIVISION NAME Jake Norman LOT NO. 512 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other _____ Porosity Good

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Not taken	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
			Rock or other impervious formations	None	

Lot Area ¾ acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Oswalt

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-27-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold