DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: William Stewart APPLICANT: Suzi Faulkner
ADDRESS: Suzi APPLICATION DATE: ___ DATE EVALUATED: 9/30/10
PROPOSED FACILITY: Dog Grooming PROPOSED DESIGN FLOW (.1949): 150gpd PROPERTY SIZE: ___
LOCATION OF SITE: 1484 Brawley School Rd PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

SE = Slightly Exp.
See Application for location of SB

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4% L	0-6	Brw SCL GR-wSBK SS	SP SE FR					PS
		6-24	Rd C mSBK SS,SP,SE	FR					
		24-48	Rd C m-wSBK SS,SP,SE	FR	w/ Common Mica Flakes				
					—	48"	—	—	.3
2	2% L	0-8	Brw SCL						
		8-10	Rd C mwSBK		Few Yellow mottles				PS
		10-48	Rd C wSBK SS,SP,SE	FR					.3
					—	48"	—	—	
					Mottles:	6/6	Low	Moist	
3	2% L	0-12"	Brw SCL	SBK SS,SP,SE	FR				
		12"-48"	Rd C/Fine m-wSBK SS,SP		SE FR				PS
					—	48"	—	—	.3
4			Small area being evaluated & SB's were Consistant & a 150 Consistant with excavation of Old ST therefore only 3 Soil borings dug.						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	
System Type(s)	II	N/A
Site LTAR	.3	

OTHER FACTORS (.1946): Well serving Rest must stay 10ft
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Maria Dotson
OTHER(S) PRESENT: Suzi Faulkner