DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Wayne Frye APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 2-29-96
PROPOSED FACILITY: duplex apt PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: 1 1/2 x 298'
LOCATION OF SITE: McKenzie Rd - ½ mi on left lot 1 PROPERTY RECORDED: no
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 4-6%	0-2	Brwn	fr					-3
		2-14	sdy lm	fr sp 1/1					
		14-35	mssdy rcl	fr ss sp 1/1					
		35-48	mottled rcl	fr ss sp					
2	L 4-6%	0-3	Brwn	fr					-3
		3-16	sdy lm	fr sp 1/1					
		16-32	mssdy rcl	fr 1/1					
		32-48	mottled sdy cl	fr 1/1					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___