IREDELL COUNTY HEALTH DEPARTMENT 4626-84-8693

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Floyd Green Realty DATE 8-22-77 PERMIT NO.

PHONE: Business 663-7515 Home

LOCATION 1100 TR on 1115 on left

S. R. No.


SUBDIVISION NAME Brawley Farms LOT NO. 6 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash Machine Yes (✓) No ( )
Sites Suitable Yes (✓) No ( )
Lot Area ½ acre +

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/inch
Topography 2-20% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-22-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold