DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT:_____ OWNER:__ AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED: 12/15/11
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
LOCATION OF SITE:_____
WATER SUPPLY: On-Site Well__✓__ Comm. Well___ Public___ Other_____ EVAL. METHOD: Auger Boring__✓__ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-2	gr- sl						.4-.5
		2-11	subbk sicl						.35
		11-25	sbk c						
		25-36	m sbk - cl						.3
		36-90	m sbk cl			45" to soft bedrock			
2									
3									
4									
5									

AVAILABLE SPACE (.1945) ES / SITE CLASSIFICATION (.1948): ES SITE LONG-TERM ACCEPTANCE RATE: .35 if 24" ft used
EVALUATED BY: RJH OTHER(S) PRESENT:_____
COMMENTS:_____