07536

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robin D. Andrews DATE Dec 14, '87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1180 TR Beech Tree (in curve across from Morrison Lumber) TR before Kings X Rds on left S. R. No. _____

SUBDIVISION NAME CL&T LAKE Norman LOT NO. 1536 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable ~~Yes~~ 160 (✓) No ( ) LAKE

Lot Area 1.02 Ac

Character & Porosity of Soil light sandy clay


Percolation Rate 20.4

Topography 15-25%

Depth to Water Table 3'+

Rock or other impervious formations none obs.

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement




Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines ~7

Sq. Ft. 1260 Linear Ft. 420

Depth of Stone in Lines 21

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: [signature]

IMPROVEMENTS PERMIT BY David R. Hinson, RS.

COMMENTS: Relayout & permit issued 10-24-87.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold