IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 164430 PIN # 4626 88 7742 DATE March 13, 2012

OWNER Selwyn & Scott Lang APPLICANT: Scott Lang PHONE: Home/Cell # 704-202-2707 Business # 980-621-2475

SITE ADDRESS 125 Pomeroy Rd. OWNER / APPLICANT ADDRESS 103 Pier 33 Dr. #218 Mooresville 28117

SITE DIRECTIONS Brawley Sch. Rd. TR Blume TL Beechtree TR Gatehouse TR Pomeroy on left

SUBDIVISION Beech Tree Road BLOCK / SECTION LOT # TR 2 LOT AREA 2.75 Ac. DESIGN FLOW 360 gpd L.T.A.R. .3gpd/ft²

Septic Tank 1000 * Gallons: STB 825 Date 4-20-12

Pump Tank 1000 Gallons: PT 302 Date 2-11-12

Pump Make ZOELLER Model M152 Serial #

No. Nitrification Fields: 1 No. Lines 5 Linear Feet 225

Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II IIIb V V VI

System Description: PPBPS Pressure Manifold

Repair System Description: LPPPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 3

☐ Business No. Persons 6

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions * min. size

House foundation shall be min 25' from septic drainfield, 15' from tanks

INITIAL SITE SKETCH

See attached Initial Site Sketch approved by ICHD 3-14-12

Plan revised from design submitted by Toney Jacobs per owner's request

AS BUILT SKETCH

INSTALLED AS SHOWN 8-8-12

SET 2' PH

CHECKED LINES & TANKS

★ CHECK ELECTRICAL & ALARM 11-8-12 ★

BOX NOT 12" ABOVE FINISHED GRADE

ONLY 1 BREAKER

Box OK 11-9-12

ELEC OK 11-9-12

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT with plat valid without expiration.* ☒ *IMPROVEMENT PERMIT with plat valid without expiration. site plan valid 60 mo.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Selwyn Lang Date 3-16-12 Installed by: Rowan Septic Tank

IMPROVEMENT PERMIT by: Judy Melville REHS Date 3-14-12 OPERATION PERMIT by: REHS Date 11-9-12

AUTHORIZATION TO CONSTRUCT by: Judy Melville REHS Date 3-14-12 Existing System Inspected by: REHS Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant