IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 164430 PIN # 4626 88 7745 42 DATE January 11, 2011

OWNER or APPLICANT Toney Jacobs / Crescent Resources / Selwyn Lang PHONE: Business 704-663-6905 Home: 704-578-4951

OWNER or APPLICANT ADDRESS PO Box 1003, Charlotte, NC 28201

LOCATION / DIRECTIONS Brawley School Rd TR Blume. TL Beech Tree on right

SUBDIVISION Beech Tree Road BLOCK / SECTION LOT # Tract 2 LOT AREA 2.748Ac. DESIGN FLOW 360 gpd L.T.A.R. .3 gpd/ft²

Septic Tank *1500 Gallons: STB Date

Pump Tank 1500 Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 5 Linear Feet 225

Trench Width 24" min. Max. Trench Bottom Depth 36" Gravel Depth NA ☐ GRAVITY ☒ PRESSURE

☒ New System ☐ Repair ☐ Expansion System Type I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required ☒ YES ☐ NO

☒ Residence No. Bedrooms 3

☐ Business No. Persons 6

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

House foundation must be at least 25' from septic drainfield (house downslope from field) and at least 15' from tanks (house sideslope from tanks)

Comments / Conditions * Per plan specs.

INITIAL SITE SKETCH

See Plan from Toney Jacobs & Assoc. Approved by ECHD

See Revised Plan 12-22-11

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Toney C Jacobs, Agt Date 1/13/11

Improvement Permit by: Judy Melville REHS Date 1-12-11

Authorization to Construct by: Judy Melville REHS Date 12-22-11

Installed by:

Operation Permit by: Date:

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant