IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sidney Leeds DATE 10-20-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TR on 1178 TL on 1234 3/4 mi TR Stay left at forks at end. S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 525 SECTION OR BLOCK NO. 5


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3/4 acre

Character & Porosity of Soil Sandy clay + Parent material
Percolation Rate Soil borings
Topography 12% slope
Depth to Water Table 10' +
Rock or other impervious formations Hard rock 2' below Filter Field. Good Sandy site Wall.



Plot of System

Size of Tank 1060 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250'
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Sam Aswalt

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 10-20-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold