Permit # 108738 Was also issued for this lot as a bldg permit for the guest house → approved septic on computer for #108738 -ja 5-11-07

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 108738 PIN# 4626 95 2349 PIL 921 DATE 6/24/06

OWNER OR APPLICANT Lillian Johnson PHONE: Business MARIANO 704-361-0527 Home

ADDRESS 109 Long Boat Rd, Mooresville, NC 28117

LOCATION 1100, TR Poplar Grove Rd., property on (R) just down on (R)

SUBDIVISION No BLOCK / SECTION LOT LOT AREA +/- 10 AC SITE CLASS. PS DESIGN FLOW 840 L.T.A.R. .3

Septic Tank: 1500 Gallons; STB 1014 Date 10/20/06

Pump Tank: 1500 Gallons; PT 46 Date 11/2/06

Pump Make: Zoeller Model WED-1512-HI Serial No.

Nitrification Field: No. Fields 1 Square Feet 2100 Linear Feet 700

No. lines 6 @ 116' Trench Width 3' Max. Trench Bottom Depth 31"

[X] New System [ ] Repair [ ] Expansion System Type: I II III IV V VI

System Description: PM - 250 RED. 16" PBRS

Repair System Description:

Maintenance Agreement Required: [ ] Yes [X] No

Gravel Depth No [ ] Gravity [X] Pressure [ ] Slab [ ] Crawl Space [X] Basement w/plumbing [ ] Basement wo/plumbing

[X] House/Mod. Home No. Bedrooms 5

[ ] Mobile Home No. Persons

[ ] Business No. Employees

[X] Other Pool House 2

Water Supply: [X] Individual [ ] Public [ ] Community

Comments:/Conditions:

3" SCH 40 PVC

INITIAL SITE SKETCH

Comments:/Conditions:

AS BUILT SKETCH

POPLAR GROVE RD

323

7 Lines

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X date

Improvement Permit by: Wesley Sparks RS. date 6/24/06

Authorization to Construct by: Wesley Sparks RS. date 6/24/06

Installed by: Rowan Septic Tank

Operation Permit by: Wesley Sparks RS. date 5/9/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK