DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Ron Waldron OWNER: AGENT: PHONE: 664-1490
ADDRESS: 195 Harwell Rd APPLICATION DATE: 3/13/96 DATE EVALUATED: 4/2/96
Mooresville NC PROPOSED FACILITY: 3BD - 2.5 BA
PROPERTY SIZE: .615 AC
LOCATION OF SITE: Lot 45 Poplar Grove
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring X Pit Cut

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1 Recon of Harwell	T ~2%	0-5	sg sgl	FR NS NP					
		5-21	SBK hcl	FI S P	S	PS	PS	S	.3
		22-39	wkfisBK cl	FR SS SP	S	S	PS	S	
		38-48	GR ltcl	VFR SS NP					.35
2									
3									
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE: ___

EVALUATED BY: ___ OTHER(S) PRESENT: ___

COMMENTS: ___