IREDELL COUNTY HEALTH DEPARTMENT

10923

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Stephen Gagel DATE Nov. 5, '90 PERMIT NO. 2F-11-A-23

PHONE: Business _____ Home _____

LOCATION 1100 TR into Poplar Grove Bear Rt and then TL 1st Street near end on Right S. R. No. _____

SUBDIVISION NAME Poplar Grove LOT NO. 23 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes	(✓)	No	( )	Character & Porosity of Soil ps clay
Auto. Dishwasher	Yes	(✓)	No	( )	Percolation Rate fr. 35
Auto. Wash. Machine	Yes	( )	No	( )	Topography ~ 8%
Site ~~Suitable~~ PS	Yes	(✓)	No	( )	Depth to Water Table 4'+
					Rock or other impervious formations none obs.

Lot Area ~ 3/4 Ac.

Basement with Plumbing _____ Basement without Plumbing _____ No Basement

1500 g.T.



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1050 Linear Ft. 350
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by FJ Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DCH

COMMENTS: Alarm not permanently mounted yet but tested and functioning.

Operation permit

~~CERTIFICATE OF COMPLETION BY~~ DR Hinson / EHS DATE 11-5-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold