IREDELL COUNTY HEALTH DEPARTMENT 4626-96-4890

12109

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Alan Leath DATE 12/13/91 PERMIT NO. 2F-11-A-30

PHONE: Business _____ Home 875-6004

LOCATION 1100, TR into Poplar Grove bear right on Tawny Bark, TL Sycamore Loop
at end on (L) S. R. No. _____


SUBDIVISION NAME Poplar Grove LOT NO. 30 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area .76 AC

Character & Porosity of Soil P - C
Percolation Rate 3
Topography 4-6%
Depth to Water Table > 3'
Rock or other impervious formations none observed
10 Wall

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1500/1500 Gals.
Nitrification Field:
No. of Lines 6 @ 70' x 3'
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ( )

* pressure conventional

Installed by Richard Abernethy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 12/13/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold