IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Theresa Featherwood DATE 4-19-74 PERMIT NO. 93

PHONE: Business _____ Home 827-4539

LOCATION 1100 TR on 1115 TR on 1455 TL then TR 2nd Rt TL at end S. R. No. 1455

SUBDIVISION NAME Lake Norman LOT NO. 284 SECTION OR BLOCK NO. 8


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3/4 acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate 53 min/inch
Topography Slope
Depth to Water Table 8 to 10' above lake level
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
Public ( )

Installed by John Howie

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: small area to put tank in therefore pushed property line and entos line is within 50'. However it is well above lake level.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-19-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold