IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Anthony Alesi DATE 3-20-78 PERMIT NO. 38

PHONE: Business _____ Home 664-2875

LOCATION 1100 T Rd go 1115 T Rd on 1454 1st Lot on Right 1mi on Lot 34 S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 278 SECTION OR BLOCK NO. 5

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	5% to Sloping
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6' to 8'
			Rock or other impervious formations	None

Lot Area 3 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 24"

Water Supply: Individual (✓)
Public ( )

Installed by E.J. Erwin

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 3-20-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold