4627115507

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tim Bowen Realty DATE 8-4-80 PERMIT NO. 244

PHONE: Business _____ Home McKenzie Lake View Dr.

LOCATION 1100 TR 1115 TR 1455 abt 0.7mile on R

S. R. No. _____

SUBDIVISION NAME LAKE NORMAN LOT NO. 298 SECTION OR BLOCK NO. 8

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Character & Porosity of Soil Clay loam
Percolation Rate 10-15/6
Topography Slopes
Depth to Water Table 4'+
Rock or other impervious formations None observed

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 16"
Water Supply: Individual (X)
Public ( )

Installed by F. J. Ewen Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 8-4-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

2:30

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tim Bowen Realty DATE 5-22-80 PERMIT NO. 156

PHONE: Business _____ Home _____

LOCATION 1100 TR 1115 TR 1455 ½ Mile on R

SUBDIVISION NAME Lake Norman S. R. No. _____

LOT NO. 298 SECTION OR BLOCK NO. 8

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area .8 acre

Character & Porosity of Soil Clay loam
Percolation Rate 80 mpi
Topography 10-15%
Depth to Water Table 4ft +
Rock or other impervious formations unknown

(X) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 333'
Depth of Stone in Lines 16"
Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: J. M. Bowen
for Tim Bowen Realty Inc

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Keep system as shallow as possible - Keep system at least 1ft above H2o table

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold