IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harvey Carpenter DATE 7-22-77 PERMIT NO. _____

PHONE: Business 364-6300 Home 596-2627

LOCATION 1100 TR on 1115 Turn right on 1455 .9mi on right S. R. No. 1455

SUBDIVISION NAME Lake Norman LOT NO. 309 SECTION OR BLOCK NO. 8


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Soil Borings
Topography 40% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 800 Linear Ft. 250
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Godwin Septic Tank Co. Charlotte, N.C.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: New Tank was used.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-22-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold