IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 375.00 Pd 9 3.00 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM IN ...ON

PERMIT# 13145 PIN# ~~4626-07-1828.520~~ 4627-21-1129 DATE Sept 29, 05

OWNER OR CONTRACTOR The Farms, LLC PHONE: Business (704) 660-1185 Home

ADDRESS 2214 Brawley Sch Rd, Mooresville, N.C. 28117

LOCATION Brawley Sch Rd / TR McKendree TR Lakeridge Shores Loop TL ~~Goose Creek Way~~ Colvard Farms on Right at end

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 520 LOT AREA 1.011ac SITE CLASS. PS DESIGN FLOW 460gpd L.T.A.R. .25

Septic Tank: 1000gal Gallons; STB 338 Date 4-24-07

Pump Tank: 1000 Gallons; PT 283 Date 6-11-07

Pump Make: Goulds Model WE(3)2HM(3) Serial No.

Nitrification Field: No Fields 1 Square Feet 640/960 Linear Feet 320

No Lines 3 (CE) Trench Width 24"min/36"max Max Trench Bottom Depth 36" Gravel Depth NR

☒ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LPP PBPS

Repair System Description: LPP PBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments/Conditions: or 36" max 9'oc

detailed site evaluation and system design performed by Paul Pennington and Kathleen Haven of S&ME

INITIAL SITE SKETCH

SEE Plan from S&ME

Comments/Conditions: Drilled 5/32" hole

8/31/07 Checked tanks, lines & pressure

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kathleen Haven date 9/30/05 Installed by: Richard Alperin Cathy RS

Improvement Permit by: [signature] date 9-29-05 Operation Permit by: Maria Dolan date 11/20/07

Authorization to Construct by: [signature] date 4/5/07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK