IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

3500 Pg 9 2100

PERMIT# 131455 PIN# ~~4626 07 1828.522~~ 4627-21-4127 Reare DATE Sept 29, 05

OWNER OR CONTRACTOR The Farms, LLC / Learch Construct PHONE: Business (704) 660-1185 Home 883-4811

ADDRESS 2214 Brawley School Rd, Mooresville, N.C. 28117

LOCATION Brawley School Rd, TR McKendree TR Lakeview Shores Loop TL Grove Creek Way TR Hammersmith Farms Ln. on left

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 522 LOT AREA .754 Ac SITE CLASS PS DESIGN FLOW 460gpd L.T.A.R. .25

Septic Tank: ~~1500~~ 1500 Gallons; STB 444 Date 11/26/07

Pump Tank: 1000 Gallons; PT 433 Date 1/11/07

Pump Make: Goulds Model WE0 3122M Serial No.

Nitrification Field: No. Fields 1 Square Feet 640/960 Linear Feet 320

No Lines 3 (CF) Trench Width 24" min 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments/Conditions: ~~or~~ 36" max 9'cc

Initial site evaluation and system design performed by Paul Pennington and Kathleen Hewes of S&ME.

INITIAL SITE SKETCH

SEE Plan from S&ME

Comments/Conditions: 10/9/06 Reviewed Site plan & Floor plans, House will fit but must stay as shown on site plan (no more than 30ft from right side line) ME

AS BUILT SKETCH

*Deck must not extend over deck

Lines, tanks & pressure checked by WS 2/28/07

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kathleen Hewes date 9/30/05

Improvement Permit by: [signature] date 9-29-05

Authorization to Construct by: Maria H Nelson RS date 10/9/06

Installed by: Richard Adams RS.

Operation Permit by: Maria H Nelson date 4/27/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK