DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES

SITE / SOIL EVALUATION
FOR
SANITARY SEWAGE SYSTEM

OWNER: Mike Griffin PHONE: 664-9116 DATE REQUESTED: _____ DATE EVALUATED: 5/17/96

ADDRESS: _____ PROPERTY IDENTIFICATION NO.: 2LB A 321

COUNTY: _____ PROPERTY SIZE: ~ .8 Ac PROPOSED FACILITY: 4-3BR

LOCATION OF SITE: Sec 8 Lot 321 end of Goat Hill Rd.

WATER SUPPLY: On-Site Well X Community _____ Public _____ EVALUATION BY: Auger Boring _____ Pit _____ Cut _____

FACTORS	PROFILE 1	PROFILE 2	PROFILE 3	PROFILE 4	PROFILE 5
LANDSCAPE POSITION	T L				
SLOPE (%)	2-10				
HORIZON I DEPTH	0 - 8				
Texture Group	l - cl				
Consistence	FR SS NP				
Structure	SBK				
Mineralogy					
HORIZON II DEPTH	9 - 24				
Texture Group	cl				
Consistence	FR SS NP				
Structure	SBK				
Mineralogy	1:1				
HORIZON III DEPTH	25 - 33				
Texture Group	scl				
Consistence	FR SS NP				
Structure	GR				
Mineralogy	1:1				
HORIZON IV DEPTH	34 - 48				
Texture Group	l > SAP				
Consistence	VFR SS NP				
Structure	FGR				
Mineralogy	1:1				
SOIL WETNESS	S				
RESTRICTIVE HORIZON	PS				
SAPROLITE	PS				
CLASSIFICATION	.35				
LONG-TERM ACCEPTANCE RATE	"				

SITE CLASSIFICATION: PS - Pres PPBS/REPAIR SITE LONG-TERM ACCEPTANCE RATE: ~ .35

EVALUATED BY: OTHER(S) PRESENT:

REMARKS: Need Survey - OLD WELL PROPERLY ABANDONED

LEGEND

LANDSCAPE POSITION
- R - Ridge
- S - Shoulder slope
- L - Linear slope
- FS - Foot slope
- N - Nose slope
- H - Head slope
- Cc - Concave slope
- Cv - Convex slope
- T - Terrace
- FP - Flood Plain

TEXTURE
- s - sand
- ls - loamy sand
- sl - sandy loam
- l - loam
- si - silt
- sil - silt loam
- sicl - silty clay loam
- cl - clay loam
- scl - sandy clay loam
- sc - sandy clay
- sic - silty clay
- c - clay

CONSISTENCE

MOIST
- vfr - very friable
- fr - friable
- fi - firm
- vfi - very firm
- efi - extremely firm

WET
- Ns - non-sticky
- Ss - slightly sticky
- S - sticky
- Vs - very sticky
- Np - non-plastic
- Sp - slightly plastic
- P - plastic
- Vp - very plastic

STRUCTURE
- sg - single grain
- m - massive
- cr - crumb
- gr - granular
- sbk - subangular blocky
- abk - angular blocky
- pl - platy
- pr - prismatic

MINERALOG
- 1:1, 2:1, mixe


Use the above standard abbreviations.

NOTES:
- Horizon Depth -- in inches
- Depth of Fill -- in inches from land surface
- Restrictive Horizon -- thickness and inches from land surface
- Saprolite -- S (suitable) or U (unsuitable)

NOTES:
- Soil Wetness -- Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less -- record Munsell color chip designation
- Classification -- S (suitable), PS (provisionally suitable) or U (unsuitable)
- Long-Term Acceptance Rate -- gal/day/ft²

DHS 2601 (Revised _____)
Sanitation Branch (Review _____)

1" = 30


115
+ -21.55
NAIL
105
+ -13.95
NAIL
4
3
2
1
5
6
24
23
21
22
25
26
15
16
8
19
10
17
14
13
12
11
7
6
18
20
28
27
3'
36'
76
1.63
6.RB
101
2.74
6.RB