IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dwight Honeycutt DATE 7-24-84 PERMIT NO. 234

PHONE: Business _____ Home _____


LOCATION 1100 SR 1115 TR dirt ROAD PAST 257 (Pigs Road) near end on R S. R. No. _____

SUBDIVISION NAME LAKE Norman LOT NO. 353 SECTION OR BLOCK NO. 8

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam w/ weathered rock
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	0.5 gal/ft²/day
Auto. Wash. Machine	Yes (X)	No ( )	Topography	10-15%
Site Suitable	Yes (X)	No ( )	Depth to Water Table	4+ ft
Lot Area 0.61 ACRE			Rock or other impervious formations	Rock 065



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1050 Linear Ft. 360
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public

Installed by J.R. Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____ DATE _____

IMPROVEMENTS PERMIT BY Jack Clemmer & Charles Barnett

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Jack Clemmer DATE 7-24-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

2:00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dwight Hargett DATE 3-2-84 PERMIT NO. 38

PHONE: Business _____ Home _____

LOCATION 1100 TR 1115 past 1157 TR dirt road end on R
Lake Norman S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 353 SECTION OR BLOCK NO. 8


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(X)
Auto. Dishwasher	Yes	(X)	No	( )
Auto. Wash. Machine	Yes	(X)	No	( )
Site Suitable	Yes	(X)	No	( )

Lot Area .61 acres

Character & Porosity of Soil clay loam
Percolation Rate .5 gal/ft²/day
Topography 10-15%
Depth to Water Table 4'+
Rock or other impervious formations None observed



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1080 Linear Ft. 360'
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by Lake

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Dwight Lee Hargett

IMPROVEMENTS PERMIT BY Charles K. Barnett

COMMENTS: Keep shallow and follow contour at 1 ft. cover on bed on down hill side

CERTIFICATE OF COMPLETION BY _____ DATE _____
EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold