ENVIRONMENT AND NATURAL RESOURCES
ENVIRONMENTAL HEALTH
STEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Crescent Resources Farms V — APPLICATION DATE ___
DDRESS: ___ — DATE EVALUATED: ___
ROPOSED FACILITY: House — PROPOSED DESIGN FLOW (.1949): 480 — PROPERTY SIZE: ___
OCATION OF SITE: Lot 622 — PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other ___
VALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut — TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1948 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 REDOX MORPH	PROFILE CLASS & LTAR
1	Pit 202 L ~4%	0-4	Mo, Gr, SL	Fr, NS, NP (Br)					PS 0.30
		4-8	Wk, sbk, scl	Fr, SS, SP (Br)					
		8-21	Mo, sbk, C	Fr, SS, SP (Red)					
		21-48+	Wk, sbk, CL	Fr, SS, SP (Red)	C-SAP Inclus.				
2	Pit 203	0-4	Mo, Gr, SL	Fr, NS, NP (DK Br)					PS 0.30
		4-17	Wk, sbk, SCL	Fr, SS, NP (Br)					
		17-36	Wk, sbk, SCL	Fr, SS, SP Br	F-C SAP Inclus				
		36-48+	Mass. SL SAP	Fr (Multi)					
3	L	0-5	Mo GR SL	FR SS/SP	Br				0.3
		5-24	Mo SBK C	FR SS/SP	Red				
		24-50	WK SBK/ABK CL	FR SS/SP	Red		F/C SAP		
		50-58	MA SL SAP	FR NS/NP	Red Br				
4	L 670	0-6	WK GR SL	FR SS/SP	Br				0.3
		6-50	WK SBK C	FR SS/SP	Red		F Black (organic)		
		50-56	MA L SAP	FR SS/SP	Red yel				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: Approved ICHD JM 3-20-07
OTHER(S) PRESENT: ~~Reapproved ICHD MS~~ 11/29/12
COMMENTS: ___