PERMIT TO INSTALL SEPTIC TANK

Permit NO. 264 Permit Date 11-28-1972

Owner Hooper Address Charlotte, NC.

Installed By Field Engineering Address Mooresville

Location of Property 1115 to 1215 Rear left at forks first spur Rt to left

Tank		Capacity		Length of Lines		Fixtures	
Block	( )	1000	( )	225'	( )	No. of Baths	(1)
Precast	(✓)	1250	( )	250'	( )	Dishwasher	(no)
		1500	( )	Other 150'		Garbage Grdr.	(no)
		Other				Other No washing machine	

NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED.

Final Inspection 19 Approved ( ) Disapproved ( )

Remarks For One Trailer. System was installed in hard bedrock - very little soil that will percolate. System has over 40 Tons of stone. Standard Job requires 24 Tons. approved on construction.

