III B 4627507441

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Sink DATE Feb 11, 87 PERMIT NO. 62

PHONE Business _____ Home _____

LOCATION 1100 TR 1115 . TR 1215 (Courtappen) left at forks 1/4 mile TR Rhinehill Dr. at end

SUBDIVISION NAME L.N. LOT NO. 426 SECTION OR BLOCK NO. 8 S. R. No. _____

Sewer Easement on Creek Lot 2 on 1215

House ✓ Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3


Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area NA

Character & Porosity of Soil Easement Area clay
Percolation Rate ~1.4
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ___/___ No Basement

1000 gal pump tank



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by J.J. Erwin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY JCM

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D.R. Hinson, RS. DATE Feb 11, 87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold