IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tony Hicks DATE 8-14-23 PERMIT NO. 251

PHONE: Business 360-1110 Home 535-2262

LOCATION 120 Feb on the Fox Trail Rd off 1457

The 2nd 1400 gal and

S. R. No.

SUBDIVISION NAME Fox Trail Shores LOT NO. 283 SECTION OR BLOCK NO. 2

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 acre


Character & Porosity of Soil Clay loam Sandy Clay

Percolation Rate 30 minutes

Topography Slight slope

Depth to Water Table 40 in

Rock or other impervious formations [redacted] Rock at 40 in



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 225 Linear Ft. 250

Depth of Stone in Lines 24 in

Water Supply: Individual (✓)

Public ( )

Installed by J.R. Lewis

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY Peter Hunter DATE 11-1-23

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Terry Mabry DATE 2-9-15 PERMIT NO. 215

PHONE: Business 704-902-1211 Home Terry Cell

LOCATION Hwy 70 E on left then TR on Mt Mourne Rd TR on Hall at end S. R. No. 1113

SUBDIVISION NAME Home Place LOT NO. 323 SECTION OR BLOCK NO. 3

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area 3 Acres


Character & Porosity of Soil Saprolite from Granite

Percolation Rate 2nd Soil

Topography Lot slopes to the rear

Depth to Water Table _____

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 225 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Set distribution Box on concrete slab
Install leaf PVC run tank line from Box to each ditch. Maintain 24" Lateral lines

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold