IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. G. Malone DATE May 8, 1979 PERMIT NO. 131

PHONE: Business _____ Home _____

LOCATION 1100 TR. on 1115 TR on 1215 ~ 1 mi. on Rt.


SUBDIVISION NAME Lake Norman LOT NO. 455 SECTION OR BLOCK NO. 8 S. R. No. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay Loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk.
			Rock or other impervious formations	none obs.

Lot Area 3/4 Ac.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Leon Thompson

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE May 8, 1979

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold