4627 08504

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don Winkler DATE 6-26-75 PERMIT NO. 142

PHONE: Business 536-4041 Home

LOCATION 1100 Rd on 1115 Rd on 1215 Core Right at Fork 1/2 mi on right S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 456 SECTION OR BLOCK NO. 8

(CL+T) Sit: 397 Grasshopper Cir - Mrsvl.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay loam Porosity fair
Percolation Rate Not Taken
Topography 12% Slope
Depth to Water Table 10 ft
Rock or other impervious formations None

Lot Area 1/2 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by F. J. Erwin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 6-26-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT 4627 $40 #504

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don Walsh DATE 6-18-25 PERMIT NO. 1823

PHONE: Business 536-4011 Home _____

LOCATION 1100 Troy 115 Troy 115 Bear Pelt at Park Union Right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 456 SECTION OR BLOCK NO. 8


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay loam loose
Percolation Rate Not Taken
Topography 2 to 5% Slope
Depth to Water Table 10 +
Rock or other impervious formations None

Lot Area ½ acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY John Hamilton

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold