1:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 094897 PIN# 4627612569 DATE 3/23/2001

OWNER OR CONTRACTOR Margaret Klutz PHONE: Business _____ Home (704)633-8896

ADDRESS 520 S. Fulton St. Salisbury NC 28144

LOCATION Brawley School Rd TR, McKendree TR Grasshopper bear Hatfork on left 311 Grasshopper

SUBDIVISION CL&TJ BLOCK / SECTION 8 LOT 44/1 LOT AREA .84 Acre SITE CLASS. DS DESIGN FLOW 360gpd A.R. _____ Pool room

Septic Tank: 1000 Gallons; STB 760 Date 12-2-00

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields _____ Square Feet _____ Linear Feet _____

No Lines Bed Trench Width EXISTING Max Trench Bottom Depth _____ Gravel Depth _____

☐ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Existing Gravity-Conventional

Repair System Description: _____

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 3

☐ Business No. Employees _____

☐ Other _____

☒ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: Existing Drainfield appears to be Functioning okay at time of inspection.

Grasshopper Circle

Comments:/Conditions: ★ Install New Septic Tank (ST) 5' from "Addition". Remove Old ST, use existing Drainfield Grey filter installed

INITIAL SITE SKETCH

★Not to Scale

Existing well

Drive

70'

~120'

New 5'

Proposed Addition

5'

12'

Existing

N5'x50'

Existing House

existing ST to be Abandoned

~82'

Lake Norman

AS BUILT SKETCH

Drainfield

N10'

PL

Installed as Drawn

Old tank abandoned in place

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ✗ Margaret M. Klutz date _____ Installed by: Myers Septic

Improvement Permit by: Maria H. Dotson RS date 3/23/2001 Operation Permit by: Maria Dotson RS date 5/31/2001

Authorization to Construct by: Maria H. Dotson RS date 3/23/2001 Existing System Inspection by: _____ date _____

Pd $125.00 3/23/2001 Check #732

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK