4627-61-2794

1974

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jason Greenman DATE July 26 '91 PERMIT NO 2C2A442

PHONE Business _____ Home _____

LOCATION 1100 TR 1115 TR 1215 (Grasshopper) Bear left at forks ~¼ mile on left

SUBDIVISION NAME CLAT / LAKE Norman LOT NO. 442 SECTION OR BLOCK NO. 8 S. R. No. _____

House w/ Mobile Home ( ) Business ( ) Other Addition

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Survey PS	Yes (✓)	No ( )	

Character & Porosity of Soil sandy clay

Percolation Rate 1"


Topography ~10-15%

Depth to Water Table mtn.

Rock or other impervious formations numerous rocks encountered in trenches

Lot Area Existing

Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓



Plot of System

Size of Tank 1000 g.l. Existing Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. _____ Linear Ft. 150' ea

Depth of Stone in Lines 16" to 24"

Water Supply: Individual (✓) panels pressure-load

Public ( )

Installed by Collet Construction

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Alarm tested & working but not permanently mounted yet.

Operation Permit

CERTIFICATE OF COMPLETION BY DR Hunter, RS DATE 7-26-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold