IREDELL COUNTY HEALTH DEPARTMENT

Owes 5?

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 151129 PIN # 4627672934.000 DATE 2/26/09

OWNER or APPLICANT Doris Elizabeth Anderson PHONE: Business Home:

OWNER or APPLICANT ADDRESS 300 Siminon Tree Road Charlotte NC 28270

LOCATION / DIRECTIONS 150 w TL Paradise Peninsula Dr. at end of road on left 105 Peninsula Dr.

SUBDIVISION CL & T BLOCK / SECTION 10 LOT # 194 LOT AREA .86 DESIGN FLOW 480 L.T.A.R. .35

Septic Tank 1000 Gallons: STB 1012 Date 6/24/08

Pump Tank 1000 Gallons: PT 19 Date 4/15/08

Pump Make Goulds Model WE20-512HHA Serial # 2/09

Nitrification Field No Fields 1 No Lines 3 Linear Feet 230

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A ☐ GRAVITY ☐ PRESSURE

☑ New System ☐ Repair ☐ Expansion System Type I II III (IV) V VI

System Description: LPPPBPS

Repair System Description: Pre treatment Panel + Ext bed

Maintenance Agreement Required ☑ YES ☐ NO

☑ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☑ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: Existing Bed to be used as partial repair also pretreatment TS II Panel Repair. See attached plans by Rollans Soil & Env. Services.

Comments / Conditions

INITIAL SITE SKETCH

See Plans by Rollans Soil & Environmental Services, Inc.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date 2-26-09

Improvement Permit by: Anthony Cohen Jr. RS. Date 2/26/09

Authorization to Construct by: Anthony Cohen Jr. RS Date 2/26/09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: David Gourley

Operation Permit by: Wesley Sparks REHS Date: 4/17/09

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant