## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ed Halcomb DATE 8-14-75 PERMIT NO. 146

PHONE: Business _____ Home _____

LOCATION 150 West TL on 1211 Just before end on right S. R. No. _____

SUBDIVISION NAME Jake Norman LOT NO. 200 SECTION OR BLOCK NO. 10


House ( ) Mobile Home ( ) Business ( ) Other Existing House Adding bath

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Sandy Clay Porosity Fair
Percolation Rate Not Tested
Topography 3 to 5% Slope
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area ½ acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 400 Linear Ft. 160
Depth of Stone in Lines 20"
Water Supply: Individual (✓)
Public ( )

Installed by E. J. Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-14-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold