209 Paradise Peninsula 4627687277

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR R.W. Hutchinson DATE 12-1-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 west TL on 1211 leave enton left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 188 SECTION OR BLOCK NO. 10


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Sandy Clay loam (Porosity Fair)
Percolation Rate 45 min/inch
Topography 10% Slope
Depth to Water Table 8' to lake level
Rock or other impervious formations Some subsurface rock.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by _____ & well

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold