IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ben Brown Jr. DATE 5-4-77 PERMIT NO. 90

PHONE: Business _____ Home 664-3256

LOCATION 150 W 21 on 1211 4th lot on right

S. R. No. _____

SUBDIVISION NAME Lake Brown LOT NO. 207 SECTION OR BLOCK NO. 10

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	✓	No	
Auto. Dishwasher	Yes	✓	No	
Auto. Wash. Machine	Yes	✓	No	
Site Suitable	Yes	✓	No	

Lot Area 2 acre


Character & Porosity of Soil Sandy loam / Material from Creek

Percolation Rate Soil Loose

Topography 2-3% Slope

Depth to Water Table 10'+

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 225 Linear Ft. 250'
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Atkinson

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 5-4-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold