4627719545

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ricky Shuping DATE 7-22-24 PERMIT NO. 181

PHONE: Business _____ Home _____

LOCATION 1120 TR on 1128 Turn TL on 1442 TL on 1440 Go 1 mi on right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 53 SECTION OR BLOCK NO. 9

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 3 acre


Character & Porosity of Soil Clay Loam

Percolation Rate 60 min/in

Topography Hilly

Depth to Water Table 10 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200'
Depth of Stone in Lines 24"

Water Supply: Individual (✓)
Public ( )

Installed by T.O. Burke

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Thurston DATE 7-29-24

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold