IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Elmer Horton DATE 11-8-79 PERMIT NO. 390

PHONE: Business _____ Home _____

LOCATION 1100 Ron 1178 To Ron 1443 To Ron 1444 TR on Honeysuckle Lane At end on Rt. S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 43 SECTION OR BLOCK NO. 9


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area .64 AC.

Character & Porosity of Soil sandy clay loam
Percolation Rate 30 mpi
Topography 4-6%
Depth to Water Table sunk.
Rock or other impervious formations some scattered rock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. _____ Linear Ft. 100' panels
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )

Installed by Maynard Hinson

IMPROVEMENTS PERMIT BY M. R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY M. R. Hinson DATE 11-8-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold