IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Walton McKinley DATE 4-18-02 PERMIT NO. 509

PHONE: Business _____ Home 535-3851


LOCATION 1000 TR on 1128 Hwy 21 Low 1443 Then
R on 1444 Then Tom Blackburn Lane 500 on left S. R. No. 1446

SUBDIVISION NAME Lake Norman LOT NO. 36 SECTION OR BLOCK NO. 9

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area large

Character & Porosity of Soil Clay loam Rock at the rock
Percolation Rate good
Topography Slope
Depth to Water Table 5' to lake level
Rock or other impervious formations none



Plot of System Lake

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 250
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
Public ( )
well may be located as per this lake

Installed by E J Smith

IMPROVEMENTS PERMIT BY [signature]

COMMENTS: Bottom of ditch is 3' above Lake level

CERTIFICATE OF COMPLETION BY [signature] DATE 4-18-02

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold