2nd
10350

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Cordle DATE May 7 '87 PERMIT NO.

PHONE: Business Home

LOCATION 1100 TR1178 (Blume) TR 1443 TR 1444 (Beaton Path) ~1/2 mile on Rt. S. R. No.

SUBDIVISION NAME L.N. LOT NO. 69 SECTION OR BLOCK NO. 9

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 3 (Lake)

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes ( ) No ( )

Lot Area ~3/4 AC

Character & Porosity of Soil Sandy clay (mottled)


Percolation Rate 2.4

Topography 10-15% 50%

Depth to Water Table 3'+ with French Drain

Rock or other impervious formations none obs.

( ) Basement with Plumbing ( ) Basement without Plumbing (✓) No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Lot Line

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: for ABS

IMPROVEMENTS PERMIT BY Steve Hyman, RS.

COMMENTS: Install drainfield shallow (12" cover) and follow contour. Install interceptor drain around system to a depth of at least 1 foot below drainfield and take to "daylight" ie the lake

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold